

This is an ADU unit in Fremont. The city required us to provide a survey. Please see attached engineering comment # 3:  
Site Design Requirements:

3. The proposed detached ADU is within 24 inches of the minimum side yard setback, thus a boundary survey performed by a **California-licensed Land Surveyor** will be required to certify the ADU setback, after the completion of the project; refer to link:

<https://www.fremont.gov/DocumentCenter/View/43318/Boundary-Survey-Requirement-Exhibit-for-Single-Family-Homes-ADU>